

1hr Fire Roller Shutters (LPCB)



Technical Specifications

Roller Curtain

The shutter curtain is constructed from cold rolled galvanised steel laths, 76 mm x 20swg. Each lath is retained by pressed steel endlocks fixed and secured by steel rivets.

Bottom Rail

Formed from mild steel flat bars bolted back to back through a centrally located galvanised steel flat quirk.

Side Guides and Angles

A purpose cold rolled mild steel section of 50mm depth. Mild steel angles of suitable size and thickness are supplied to support the side guides and to form a secure fixing to the structure.

Roller Bracket Plates

Of suitable design, and 3 mm thick. Fitted with suitable cleats for fixing to the structure.

Operation

Self-coiling shutters are manually operated i.e. push-up/pull-down. The roller barrel is manufactured from 101mm 16swg tube and contains suitable sized springs to counter-balance the shutter. In a fire situation, a solder fusible link melts at 72°C, releasing the shutter via a drop-bar.

Hand chain operated shutters are fitted with a gearbox unit complete with low level hand chain to open the shutter and a brake release cord, to close the shutter. The roller barrel is manufactured from mild steel tube of suitable outside diameter and wall thickness to suit the shutter application, and is unsprung. The gearbox contains a controlled descent mechanism. A fusible link backup facility is provided as standard. A solenoid release mechanism is available which provides a manual test and reset facility, and can be connected to a fire alarm system (by others).

Electrically operated shutters are fitted with a motor/gearbox unit complete with a push button station with "UP", "DOWN" and "STOP" buttons. The roller barrel is manufactured from mild steel tube of suitable outside diameter and wall thickness to suit the shutter application, and is unsprung. The gearbox contains a controlled descent mechanism and a brake release cord to close the shutter in the event of a power failure. A solenoid release mechanism is available which provides a manual test and automatic reset facility, and can be connected to a fire alarm system (by others- Solenoid release mechanism requires a 24 volt signal at 1 amp and up to 3 amp start up current upon activation of the fire alarm system).

Audio-Visual Panel

A popular extra for fire shutters is an audio-visual panel which provides a warning that the shutter is about to close automatically via the fire alarm system. The panels require a 240 volt supply together with an appropriate signal from the fire alarm system (by others).

Finish

Side guides, supporting angles and door curtain are galvanised. Non-galvanised sections are primer painted. Powder coated finish is optional and can be provided at extra cost.

Coil Casing

Coil casings are supplied as standard and are manufactured from 20 swg galvanised sheet steel.

Test Report

Loss Prevention Certification Board Reference No. 165a/04.
Test Report No. 208422 - BS 476 Part 22 1987.
BRE Assessment No. CC208825 Review 2.

Size/Weight

Maximum certified size of shutters is 2.2 m x 2.2 m (5 m²) and shutters weigh approximately 35 kg per m²

Head Office
Industrial Door Engineering
Winnington Avenue
Northwich
Cheshire
CW8 4EQ



Web www.industrial-door-eng.co.uk
Email sales@industrial-door-eng.co.uk
Tel 01606 563045
Fax 01606 871482

Covering North and Mid Wales, The Midlands,
The North West and Yorkshire